

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

75  
आज़ादी का  
अमृत महोत्सव

No. F6/DFS/MS/School/WZ/2025/ 1240

Dated:- 08/10/2025

**FIRE SAFETY CERTIFICATE**

Certified that the D. S. Memorial Public Sr. Sec. School Located at Extension, 2-C, Nangloi, Delhi-110041, comprised of Block-I = Basement + Ground + 02 Upper Floor & Block-II = Ground + 02 Upper Floor owned/occupied by D. S. Memorial Public Sr. Sec. School, was issued Fire Safety Certificate by this department Vide Letter No. F6/DFS/MS/School/WZ/2022/1086 Dated 29/09/2022. The said premise was re-inspected by the officer concerned of this department on 26/09/2025 in the presence of Sh. Mahipal Yadav, (Owner) and found that the premises/building have deemed complied with the fire prevention and fire safety requirements in accordance D.O.E. Cr. No. 3298-3398 dated 01.03.2011 / NBC (Part-IV) and that the premises/building is fit for occupancy class "Educational Building" Group B with effect from 08/10/2025 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules, 2010, printed below.

Issued on ... 08/10/2025 ... at New Delhi by.

  
M.K. Chattopadhyay  
Dy. Chief Fire Officer  
West Zone

Copy to: -

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi – 110054.
2. The Principal, D. S. Memorial Public Sr. Sec. School, Extension, 2-C, Nangloi, Delhi-110041

**Conditions for validity of fire safety certificate:-**

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.
9. The basement shall be used as per BBL.